

TO: Ron Robinson, Mike Price  
FROM: Darrel Anderson  
SUBJECT: McCleary STP  
DATE: August 30, 1973

State of  
Washington  
Department of  
Ecology



On June 24, 1973, I conducted an efficiency study on McCleary sewage treatment plant. The facility has good security but is not as clean as it should be. There is no trained operator for the plant and several city employees share maintenance and lab work.

The 5-day BOD reduction is 66 percent, COD reduction is 59 percent. Fecal coliform did not surpass 200/100 mls and fecal strep was less than 20/100 mls. Total solids reduction was 31 percent.

DA:bjj

STP SURVEY REPORT FORM  
(EFFICIENCY STUDY)

City McCleary Plant Type L. Filter Population 1300 Design ?  
 Served Capacity  
 Receiving Water Wildcat Creek via Ditch Engineer Chuck Melville  
 Date 7-24-73 Survey Period 0830-1630 Survey Personnel Darrel Anderson  
 Comp. Sampling Frequency 1/2 hour Weather Conditions Clear  
 (last 48 hours)  
 Sampling Alequot 1,000 ml

PLANT OPERATION

Total Flow 451,000 gpd How Measured flow meter  
 Max. (Flow) 32,000 Time of Max. 1530 Min. 28,000 Time of Min. 1200-1300  
 Pre Cl<sub>2</sub> -- #/day Post Cl<sub>2</sub> 4-6 #/day

FIELD RESULTS

Determinations	Influent				Effluent			
	Max.	Min.	Mean	Median	Max.	Min.	Mean	Median
Temp. °C	20.0	17.0	17.4	17.0	19.0	17.0	17.7	18.0
pH	7.4	6.9	7.0	7.1	7.0	7.0	7.0	7.0
Conductivity (umhos/cm)	500	400	453	450	450	375	420	450
Settleable Solids	6.2	3.5	5.0	5.0	Trace			

LABORATORY RESULTS ON COMPOSITE IN PPM

Laboratory Number	Influent	Effluent	% Reduction
	73-2705	73-2706	
5-Day BOD	90	31	66
COD	270	111	59
T.S.	382	267	31
T.N.V.S.	202	159	22
T.S.S.	142	27	81
N.V.S.S.	10	12	--
pH	7.4	7.6	--
Conductivity	640	550	--
Turbidity	55	17	--

McCleary STP

BACTERIOLOGICAL RESULTS

$\text{Na}_2\text{S}_2\text{O}_3$  added to sample before sample After was taken.      min.

LAB #	SAMPLING TIME	COLONIES/100 MLS (MF)	Cl Residual	
			ppm	(after secs)
73-2707	0945	<100	0.2	0.2
73-2708	1030	<100	0.2	0.2
73-2709	1200	<200	0.15	0.3
73-2710	1330	<200	0.15	0.2
73-2711	1430	<200	0.2	0.4
73-2712	1600	<20	0.3	0.5

Operator's Name No trained operator Phone #     

Comments:     

MBAS - Average 12.4

Chlorides - Inf. 41

Eff. 44

Fecal Strep <20 all samples

STATE OF WASHINGTON  
**DEPARTMENT OF ECOLOGY**  
 WATER QUALITY LABORATORY

ORIGINAL TO:  
B. Anderson  
 COPIES TO:  
 .....  
 .....  
 LAB FILES

DATA SUMMARY

Source McCreary STP  
 Date Collected 7-24-73

Collected By D. A.  
 Goal, Pro./Obj. \_\_\_\_\_

Log Number:	73-2705 06 07 08 09 10 11 12								STREET
Station:	14F	EFF	0995	1030	1200	1330	1430	1600	
pH	7.4	7.6							00403
Turbidity (JTU)	55	17							00070
Conductivity (umhos/cm)@25°C	640	550							00095
COD	270	111							00340
BOD (5 day)	90	31							00310
Total Coliform (Col./100ml)			<100	<100	EST 200	<100	EST 20	EST 20	31504
Fecal Coliform (Col./100ml)			<100	<100	<200	<200	<200	<20	31616
NO3-N (Filtered)									00620
NO2-N (Filtered)									00615
NH3-N (Unfiltered)									00610
I. Kjeldahl-N (Unfiltered)									00625
O-PO4-P (Filtered)									00671
Total Phos.-P (Unfiltered)									00665
Total Solids	392	267							00500
Total Non Vol. Solids	202	159							
Total Suspended Solids	142	27							00530
Total Sus. Non Vol. Solids	10	12							
MBAS	<.05	<.05	0.80	0.35	3.4	2.8			
Fecal Strept (count/ml)			EST 100	<20	<20	<20	<20	<20	
Chlorides	41	44							

Note: All results are in PPM unless otherwise specified. ND is "None Detected"  
 Convert those marked with a \* to PPB (PPM x 10<sup>-3</sup>) prior to entry into STREET

Summary By /T. P. Bell Date 8-22-73

*Estimated*

U.S. DEPARTMENT OF THE INTERIOR  
FEDERAL WATER POLLUTION CONTROL ADMINISTRATION  
SEWAGE TREATMENT PLANT OPERATION AND MAINTENANCE  
PRACTICES QUESTIONNAIRE

FORM APPROVED  
MAY 1964 EDITION NO. 40-11327


CHECK ONE:  LIST A UNIT  LIST B UNIT  
DATE OF AUDIT: **7-24-73**  
PLANT DESCRIPTION CODE (List B or Official Use Only)

1. PROJECT (State, Number) \_\_\_\_\_  
2. PLANT LOCATION (City, County) **McCleary**  
3. POPULATION \_\_\_\_\_  
4. TYPE OF COLLECTION SYSTEM \_\_\_\_\_  
5. YEAR COMMUNITY BEGAN SEWAGE TREATMENT \_\_\_\_\_  
6. YEAR PRESENT SYSTEM BEGAN OPERATION \_\_\_\_\_  
7A. SIZE OF PLANT SITE (acres) \_\_\_\_\_  
7B. APPROXIMATE AREA LEFT FOR EXPANSION (acres) \_\_\_\_\_

8. FRACTION OF AREA POPULATION SERVED (%) **Nearly 100%**  
9. PLANT DESIGN (population equivalent) **?**  
10. EST. WASTE FLOW CONTRIBUTED BY SURFACE OR GROUNDWATER (infiltration, mgd) **Doubles during rain**  
11. EST. WASTE FLOW (mgd) \_\_\_\_\_

12. TYPE OF COLLECTION SYSTEM:  COMBINED  SEPARATE  BOTH  
13. YEAR PRESENT SYSTEM BEGAN OPERATION: 6A. SEWER \_\_\_\_\_ 6B. PLANT \_\_\_\_\_ 6C. AUXILIARY WORKS \_\_\_\_\_

14. IN THE SPACE PROVIDED BELOW PLOT AN SIMPLIFIED FLOW DIAGRAM OR A BRIEF DESCRIPTION OF THE PLANT UNITS IN FLOW SEQUENCE. INCLUDE THE METHOD OF ULTIMATE SLUDGE DISPOSAL. SHOW APPROXIMATE SURFACE SLOPE OF STABILIZATION POND AND NUMBER OF CELLS. INDICATE WHETHER FLOW TO AND FROM PLANT IS BY PUMPING OR GRAVITY.



15. NOTE ANY SIGNIFICANT OR UNIQUE PROCESSING CONDITIONS:  
**aeration units on Primary & Secondary**

16. NAME OF STREAM: **ditch TO WILDCAT CREEK**  
17. RECEIVING STREAM

18. STREAM FLOW IS:  PERMANENT  INTERMITTENT  NATURAL  REGULATED  
 INTERSTATE  INTRASTATE  COASTAL

19. CURRENT PERFORMANCE AND PLANT LOADING INFORMATION:  
19A. ANNUAL AVERAGE DAILY FLOW RATE (mgd) **?**  
19B. PEAK FLOW RATE (mgd): DRY WEATHER \_\_\_\_\_ WET WEATHER \_\_\_\_\_  
19C. MINIMUM FLOW RATE (mgd) \_\_\_\_\_

20. AVERAGE BOD OF RAW SEWAGE 5 DAY 20°C (ppm) \_\_\_\_\_  
21. AVERAGE SETTLEABLE SOLIDS OF RAW SEWAGE (mg/l) \_\_\_\_\_  
22. AVERAGE SUSPENDED SOLIDS OF RAW SEWAGE (mg/l) \_\_\_\_\_  
23. AVERAGE BOD OF TREATED EFFLUENT (ppm) \_\_\_\_\_  
24. AVERAGE SETTLEABLE SOLIDS OF TREATED EFFLUENT (mg/l) \_\_\_\_\_  
25. AVERAGE SUSPENDED SOLIDS OF TREATED EFFLUENT (mg/l) \_\_\_\_\_

26. ANNUAL AVERAGE PLANT PERFORMANCE:  
26A. BOD (%) \_\_\_\_\_ 26B. SETTLEABLE SOLIDS (%) \_\_\_\_\_ 26C. SUSPENDED SOLIDS (%) \_\_\_\_\_

7A. DOES PLANT HAVE STANDBY POWER GENERATOR FOR MAJOR PUMPING FACILITIES? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	7B. ADEQUATE ALARM SYSTEM FOR PUMP OR EQUIPMENT FAILURE? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
8. ARE CHLORINATION FACILITIES PROVIDED? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO IF YES, ANSWER 8A THRU G	IF YES, IS CHLORINATION CONTINUOUS? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO IF NO, EXPLAIN REASON FOR INTERMITTENT CHLORINATION

8A. PURPOSE OF CHLORINATION  
*DISINFECTION*

8D. TYPE OF CHLORINATOR  
*WOLLOCE & TIERNAN*

8C. POINT OF APPLICATION OF CHLORINE  
*AFTER 2nd Clarifier*

8D. CAN BYPASSED SEWAGE BE CHLORINATED?  
 YES  NO

8E. AVERAGE FEED RATE OF CHLORINE (lb/day)  
*4-6 lbs*

8F. CHLORINE RESIDUAL IN EFFLUENT  
\_\_\_\_\_ PPM AT END OF \_\_\_\_\_ MINUTES

8G. MINIMUM SUPPLY OF CHLORINE STORED ON PREMISES (lb)  
*280 lbs*

9. ARE FACILITIES PROVIDED FOR COMPLETE BYPASS OF RAW SEWAGE?  
 YES  NO IF YES, ANSWER A THRU G BELOW, ANSWER H IN EITHER CASE.

9A. FREQUENCY (times monthly)  
*Frequently during wet weather*

9B. AVERAGE DURATION (hours)  
*\_\_\_\_\_*

9C. REASON FOR BYPASSING  
*\_\_\_\_\_*

9D. ESTIMATED FLOW RATE DURING BYPASS IS  
 WITHIN HYDRAULIC CAPACITY OF PLANT  
 BEYOND HYDRAULIC CAPACITY OF PLANT BY

9E. DOES SEWAGE OVERFLOW IN DRY WEATHER?  
 YES  NO

9F. TYPE OF DIVERSION STRUCTURE  
*HEAD HOUGH*

9G. AGENCIES NOTIFIED OF BYPASS ACTION  
*RECORDED ON TABULAR SHEET*

9H. DO OPERATORS HAVE OPTION TO BYPASS INDIVIDUAL PLANT UNITS? (If no, has this caused any operational problems?)  
 YES  NO  
*Trickle filter & 2nd Clarifier*

10A. ARE BACK FLOW DEVICES PROVIDED AT ALL CONNECTIONS TO CITY WATER SUPPLY? (If no, explain)  
 YES  NO

10B. CHECK TYPE OF BACK FLOW PREVENTION DEVICE  
 DOUBLE CHECK VALVE  PRESSURE OPERATED  PHYSICAL DISCONNECT  OTHER (specify)  
*NONE*

11. USES OF TREATMENT PLANT EFFLUENT  
*NONE*

12. USES OF RECEIVING STREAM WITHIN 10 MILES OF OUTFALL  
*Fishing Recreation*

13. HAVE THERE BEEN ANY ODOR COMPLAINTS BEYOND THE PLANT PROPERTY? (If yes, explain)  
 YES  NO  
*In Summer*

14. OBSERVED APPEARANCE AND CONDITION OF EFFLUENT, RECEIVING STREAM, OR DRAINAGE WAY  
*Slightly Turbid*

15. STABILIZATION POND

A. WELLS CUT AND VEGETATIVE GROWTH IN PONDS ELIMINATED? <input type="checkbox"/> YES <input type="checkbox"/> NO	D. BANKS AND DIKES MAINTAINED (erosion etc.)? <input type="checkbox"/> YES <input type="checkbox"/> NO
C. FENCING AND WEAVING - POLLUTED WATER? SIGNS PRESENT AND IN GOOD REPAIR? <input type="checkbox"/> YES <input type="checkbox"/> NO	D. FREQUENCY OF INSPECTION BY OPERATOR
E. WATER DEPTH (ft): _____ HIGH _____ LOW _____ MEDIUM	
F. ADEQUATE CONTROL OF DEPTH? <input type="checkbox"/> YES <input type="checkbox"/> NO	G. SEEPAGE REPORTED? <input type="checkbox"/> YES <input type="checkbox"/> NO
H. ANY REPORTS OF GROUND WATER CONTAMINATION FROM POND (If yes, give details)? <input type="checkbox"/> YES <input type="checkbox"/> NO	

I. EXPOSURE TO BLEEDING PROBLEM? <input type="checkbox"/> YES <input type="checkbox"/> NO	J. IF YES, NAME OF SPECIES IF KNOWN	K. CAN SURFACE RUN-OFF ENTER POND? <input type="checkbox"/> YES <input type="checkbox"/> NO
--	-------------------------------------	--

C. SUPERVISORY SERVICES

1. IS A CONSULTING ENGINEER RETAINED OR AVAILABLE FOR CONSULTATION ON OPERATING AND MAINTENANCE PROBLEMS?  
 YES  NO IF YES IS IT ON:  CONTINUING BASIS OR  UPON REQUEST BASIS  
 IF CONTINUING BASIS, WHAT IS THE FREQUENCY OF VISITS: *City Engineer*

2. DO OPERATORS AND OTHER PERSONNEL ROUTINELY ATTEND SHORT COURSES, SCHOOLS OR OTHER TRAINING ACTIVITIES?  
 YES  NO  
 IF YES, CITE COURSE SPONSOR AND DATE OF LAST COURSE ATTENDED  
 IF NO, DO YOU KNOW OF ANY COURSES AVAILABLE TO SERVE THIS AREA?

3A. ARE ALL EQUIPMENT AND PARTS OF THE PRESENT PLANT STILL IN OPERATION?  YES  NO (If no, explain)  
*pH meter - probe - not working*

B. ARE PROCESSING UNITS OPERATING AT DESIGN EFFICIENCY?  YES  NO (If no, explain)

4. HAVE THERE BEEN ANY DIFFICULTIES WITH THE SEWAGE TREATMENT PLANT?

A. STRUCTURAL  YES  NO (If yes explain)  
*Frequent Bg PPS during wet weather*

B. MECHANICAL  YES  NO (If yes, explain)

C. OPERATIONAL  YES  NO (If yes, explain)  
*no trained personnel operating plant at this time. - awaiting schedule for classes.*

D. BASED ON OPERATING EXPERIENCE TO DATE WHAT IF ANY CHANGES WOULD YOU RECOMMEND TO IMPROVE OPERATION OF THE PLANT?  
*more time for maintenance & TESTING and time for education.*

5. ARE OPERATING RECORDS MAINTAINED?  YES  NO  
 (If maintained, check general items included)

REPORTED?  YES  NO  
 TO WHOM? *Health Dept*

FREQUENCY	WEATHER	FLOW	SLUDGE HANDLED	CHEMICALS USED	REGISTER	GRIT HANDLED	ELEC. USED	COST DATA	AIR USED	MAINTENANCE	OTHER
DAILY		<input checked="" type="checkbox"/>									
WEEKLY								<input checked="" type="checkbox"/>			
MONTHLY											
ANNUALLY											

6. ARE LABORATORY RECORDS MAINTAINED? (check appropriate box)

NOT AT ALL  DAILY  WEEKLY  MONTHLY  ANNUALLY

IF MAINTAINED CHECK FORM OF RECORD BELOW:

LOG BOOK  TABULAR SHEET  SEPARATE BY OPERATION  CONTROL CHARTS  GRAPHS

WHAT PLANT AND/OR LABORATORY EQUIPMENT, GAUGES AND METERS ARE CALIBRATED PERIODICALLY?

7. IS LABORATORY TESTING ADEQUATE FOR THE CONTROL REQUIRED FOR THIS SIZE AND TYPE OF PLANT?

YES  NO (If no, explain)

B. INDUSTRIAL WASTES DISCHARGED TO MUNICIPAL SYSTEM:	A. NUMBER AND TYPES OF INDUSTRIES DISCHARGING TO SYSTEM <i>Hospital &amp; School - Simpson Timber</i>
B. POPULATION EQUIVALENT (PEQ) OF INDUSTRIAL WASTES (pp)	C. POPULATION EQUIVALENT (PE) OF INDUSTRIAL WASTES (pp) ?
D. VOLUME OF INDUSTRIAL WASTES (mgd)	E. COMPOSITION AND CHARACTERISTICS OF INDUSTRIAL WASTES ?

F. MAIN DIFFICULTY EXPERIENCED WITH INDUSTRIAL WASTE (explain)

*None*

G. HAVE INDUSTRIAL EFFLUENT PROBLEMS BEEN SOLVED?  YES  NO (If yes, how?)

9A. METHOD OR METHODS USED TO ASSESS INDUSTRIAL WASTE TREATMENT COST (check appropriate box)

NO CHARGE BY CITY  PROPERTY TAX  WATER USE ASSESSMENT  CHARGE BASED ON FLOW

CHARGED BASED ON BOD  CHARGE BASED ON SS  OTHER METHODS (describe)

COMMENT ON HOW CHARGE IS COLLECTED (fixed charge, sliding scale, etc.)

9B. IS INDUSTRIAL WASTE ORDINANCE IN EFFECT AND ENFORCED?  YES  NO

10. WHO PROVIDED INITIAL INSTRUCTION IN THE OPERATION OF THE PLANT?

11. IS A MANUAL OF PRACTICE OR INSTRUCTIONS AVAILABLE?  YES  NO

IF YES, WHO WROTE AND PROVIDED IT? *DEPT OF ECOLOGY*

12. ESTIMATE OF MAN-HOURS PER WEEK DEVOTED TO LABORATORY WORK AND MAINTENANCE OF RECORDS AND REPORTS

*12*

D. PLANT PERSONNEL (Annual Average As of the Most Recent Year Reported in Section "E")

JOB CATEGORY	NUMBER	TOTAL MAN-HOURS PER WEEK	TOTAL NUMBER CERTIFIED OR LICENSED	RAISE IN YEARS EMPLOYED AT PRESENT PLANT	RANGE IN YEARS OF EXPERIENCE IN TREATMENT
1. SUPERINTENDENT					
2. OPERATORS					
3. LABORATORY TECHNICIANS					
4. LABORERS					
5. PART-TIME LABORERS	<i>1</i>	<i>12</i>	<i>NONE</i>		
6. TOTAL					

E. LABORATORY CONTROL

Enter test codes opposite appropriate items. If any of the below tests are used to monitor industrial wastes place an "X" in addition to the test code.

CODES

1 - 7 or more per week    3 - 1, 2, or 3 per week    5 - 2 or 3 per month    7 - Quarterly    9 - Annually  
 2 - 4, 5 or 6 per week    4 - as required    6 - 1 per month    8 - Semi-Annually

ITEM	RAW	PRIMARY EFFLUENT	MIXED LIQUOR	FINAL	SLUDGE		DIGESTOR	RECEIVING STREAM
					RAW	SUPER-NATANT		
1. BOD								
2. SUSPENDED SOLIDS								
3. SETTLEABLE SOLIDS								
4. SUSPENDED VOLATILE								
5. DISSOLVED OXYGEN							/	
6. TOTAL SOLIDS								
7. VOLATILE SOLIDS								
8. pH		BROKE DOWN						
9. TEMPERATURE								
10. COLIFORM DENSITY								
11. RESIDUAL CHLORINE				/				
12. VOLATILE ACIDS								
13. M. B. STABILITY								
14. ALKALINITY								
15.								
16.								
17.								
18.								
19.								

F. OPERATION AND MAINTENANCE COST FOR PLANT

YEAR OF OPERATION	SALARIES/WAGES	ELECTRICITY	CHEMICALS	MAINTENANCE	OTHER ITEMS	TOTAL
MOST CURRENT YEAR 19						
PRIOR YEAR 19						
PRIOR YEAR 19						
PRIOR YEAR 19						

EVALUATION PERFORMED BY	TITLE	ORGANIZATION
DARREL ANDERSON	ENVRO. TECH II	D.O.E.

INFORMATION FURNISHED BY	TITLE	ORGANIZATION	DATE
ED Biers	city of Mcdeary SUPERINTENDANT	Mcdeary	7-2-78

6. NOTATIONS BY EVALUATOR

1. ADDITIONAL REMARKS (If remarks refer to a particular item, identify by number)

2. GENERAL COMMENTS ON HOUSEKEEPING AND MAINTENANCE

Housekeeping is Fair  
Maintenance Fair

3. REQUIREMENTS OF HIGHER AUTHORITY

3A. DOES THE PLANT PROVIDE THE DEGREE OF TREATMENT PRESENTLY REQUIRED BY THE STATE? (If no, explain)

YES  NO

3B. ARE THERE ANY PENDING ACTIONS (enhancement conferences, change in water quality standards, etc.) THAT WOULD REQUIRE UPGRADING OF TREATMENT BY THIS PLANT?

YES  NO (If yes, explain)

3C. NUMBER OF STATE INSPECTIONS OF PRESENT PLANT TO DATE.

4. IS ANY FOLLOW-THRU ACTION REQUIRED TO (1) CORRECT DEFICIENCIES IN THE PLANT OR ITS OPERATION OR (2) RESOLVE INDUSTRIAL WASTE PROBLEMS? (If yes, describe required corrective action)  YES  NO

Should be at least two trained operators ~~at plant~~  
available at all times. Also more time scheduled for tests  
and maintenance.