

September 13, 1974

State of  
Washington  
Department  
of Ecology



Memo to: Ted Trepanier

From: Hans Cregg

Subject: Rainier Vista STP

On August 8, 1974, an efficiency study was conducted at the Rainier Vista Treatment Plant. The plant appeared clean and it was evident that good housekeeping practices were being followed. The plant operates fairly well (see reduction on report form) except for the high coliform level. This could be improved upon by monitoring and adjusting the chlorine feed-rate to the effluent. As can be seen from the lab results, the effluent BOD is not an absolute value, consequently the percentage of reduction is left indeterminable.

HC:jmh

STP Survey Report Form

Efficiency Study

City Rainier Vista Plant Type \_\_\_\_\_ Pop. Served \_\_\_\_\_ Design \_\_\_\_\_  
 Receiving Water Duwamish River Perennial  Intermittent \_\_\_\_\_  
 Date 8/8/74 Survey Period 8 hours Survey Personnel H. Cregg  
 Comp. Sampling Frequency \_\_\_\_\_ Sampling Alequot \_\_\_\_\_  
 Weather Conditions (24 hr) Clear Are facilities provided for complete by-  
 pass of raw sewage?  Yes  No/Frequency of bypass \_\_\_\_\_  
 Reason for bypass \_\_\_\_\_ Is bypass chlorinated?  Yes  No  
 Was DOE Notified? \_\_\_\_\_ Discharge - Intermittent \_\_\_\_\_ Continuous \_\_\_\_\_

Plant Operation

Total flow 3,935,000 GPD How measured Totalizer  
 Maximum flow \_\_\_\_\_ Time of Max. \_\_\_\_\_  
 Minimum flow \_\_\_\_\_ Time of Min. \_\_\_\_\_  
 Pre Cl<sub>2</sub> \_\_\_\_\_ #/day Post Cl<sub>2</sub> \_\_\_\_\_ #/day

Field Results

Determinations	Influent				Effluent			
	Max.	Min.	Mean	Median	Max.	Min.	Mean	Median
Temp °C	20.0	19.8		20.0	21.0	19.4		20.0
pH (Units)	7.6	7.4		7.5	7.0	6.8		7.0
Conductivity (µmhos/cm <sup>2</sup> )	650	500		600	750	500		650
Settleable Solids (mls/l)	22	18	20	20	<.1	<.1	<.1	<.1

Laboratory Results on Composites

	Influent	Effluent	% Reduction
Laboratory No.	<u>74-3259</u>	<u>74-3260</u>	
5-Day BOD ppm	<u>172</u>	<u>&lt; 200</u>	
COD ppm	<u>404</u>	<u>109</u>	<u>73%</u>
T.S. ppm	<u>428</u>	<u>260</u>	<u>40%</u>
T.N.V.S. ppm	<u>171</u>	<u>142</u>	<u>17%</u>
T.S.S. ppm	<u>188</u>	<u>37</u>	<u>81%</u>
N.V.S.S. ppm	<u>64</u>	<u>6</u>	<u>91%</u>
pH (Units)	<u>7.2</u>	<u>7.3</u>	
Conductivity (µmhos/cm <sup>2</sup> )	<u>550</u>	<u>570</u>	
Turbidity (JTU's)	<u>75</u>	<u>20</u>	

Laboratory Bacteriological Results

Lab No.	Sampling Time	Colonies/100 ml (MF)			Cl <sub>2</sub> Residual	
		Total Coliform	Fecal Coliform	Fecal Strep	15 sec	3 min
74-3261	0900	30,000	Est. 90			
3262	1100	>40,000	>4000		.15	.4
3263	1300	>40,000	2800		.15	.4
3264	1500	>40,000	>4000		.15	.5

Additional Laboratory Results

NO <sub>3</sub> -N ppm -	N.D.	
NO <sub>2</sub> -N ppm -	N.D.	
NH <sub>3</sub> -N ppm -	39	
T. Kjeldahl-N ppm -	39.3	
O-PO <sub>4</sub> -P ppm -	5.1	
T-PO <sub>4</sub> -P ppm -	11.2	

Operator's Name \_\_\_\_\_ Phone No. \_\_\_\_\_

Furnish a flow diagram with sequence and relative size and points of chlorination.

Type of Collection System

Combined     Separate     Both

Estimate flow contributed by surface or ground water (infiltration)

\_\_\_\_\_ MGD

Plant Loading Information

Annual average daily flow rate (mgd)

Peak flow rate (mgd)

Dry \_\_\_\_\_

Dry \_\_\_\_\_

Wet \_\_\_\_\_

Wet \_\_\_\_\_

COMMENTS: \_\_\_\_\_

\_\_\_\_\_

