

November 29, 1974

State of Washington  
Department of Ecology



Memo to: Bill Burwell

From: Shirley Prescott

Subject: Endicott STP Efficiency Study

A routine efficiency study was conducted on September 24, 1974 on the above subject plant.

Field and lab results are shown in attached survey form; most of which looks quite good.

Leonard Willis, plant operator is scheduled for a certification test and plans to obtain some lab equipment and implement a plan of regular testing. No particular grounds beautification but grounds are fenced and buildings in good repair.

The whole facility had just been completely cleaned out because of a sulphur loaded influent.

SP:eme

Enclosure

STP Survey Report Form

Efficiency Study

City Endicott, Wa. Plant Type Trickling Filter Pop. Served 360 Design 750  
 Capacity  
 Receiving Water Rebel Flat Creek Perennial X Intermittent \_\_\_\_\_  
 Date 24 Sept. 74 Survey Period 6 hrs. Survey Personnel Shirley Prescott  
 Comp. Sampling Frequency \_\_\_\_\_ Sampling Alequot 1,000 mls  
 Weather Conditions (24 hr) Clear & dry Are facilities provided for complete by-  
 pass of raw sewage? X Yes \_\_\_\_\_ No/Frequency of bypass \_\_\_\_\_ Emergency \_\_\_\_\_  
 Reason for bypass Sulphur loaded influents Is bypass chlorinated? X Yes X No  
 Was DOE Notified? Yes Discharge - Intermittent \_\_\_\_\_ Continuous X

Plant Operation

Total flow .12 How measured Ruler  
 Maximum flow .15 Time of Max. 9 a.m. to 1 p.m. & 4 p.m. to 6 p.m.  
 Minimum flow .03 Time of Min. Night  
 Pre Cl<sub>2</sub> None #/day Post Cl<sub>2</sub> 3 lbs. #/day

Field Results

Determinations	Influent				Effluent			
	Max.	Min.	Mean	Median	Max.	Min.	Mean	Median
Temp °C	19.2	18.2		18.6	18.8	17.1		18.0
pH (Units)	7.8	7.2		7.3	7.8	7.4		7.3
Conductivity (µmhos/cm <sup>2</sup> )	900	600		700	950	725		750
Settleable Solids (mls/l)	8.	5.	7.25		.1	trace		

Laboratory Results on Composites

	Influent	Effluent	% Reduction
Laboratory No.	3871	3872	
5-Day BOD ppm	340	40	88%
COD ppm	625	45	93%
T.S. ppm	785	533	32%
T.N.V.S. ppm	377	376	.002%
T.S.S. ppm	232	16	.93%
N.V.S.S. ppm	17	4	.76%
pH (Units)	7.3	8.1	
Conductivity (µmhos/cm <sup>2</sup> )	850	860	
Turbidity (JTU's)	90.	7.	
Chlorides	25	45.	

Laboratory Bacteriological Results

Lab No.	Sampling Time	Colonies/100 ml (MF)			Cl <sub>2</sub> Residual .15 - - 3 min.
		Total Coliform	Fecal Coliform	Fecal Strep	
3873	10:30	19,000		<10	1. -- 1.
3874	12:00	12,000	140 Est.	420	1. -- 1.
3875	13:45	5,500	90 Est.	150 Est.	.75 -- 1.
3876	14:30	41,000	1,100 Est.	440	.75 --- 1.

Additional Laboratory Results


NO <sub>3</sub> -N ppm	-	1.52
NO <sub>2</sub> -N ppm	-	ND
NH <sub>3</sub> -N ppm	-	5.4
T. Kjeldahl-N ppm	-	6.4
O-PO <sub>4</sub> -P ppm	-	0.62
T-PO <sub>4</sub> -P ppm	-	265

Operator's Name Leonard W. Willis Phone No. 657-3412

Furnish a flow diagram with sequence and relative size and points of chlorination.

Chlorination  
Camber Size App.  
4 ft. X 15 ft.- 6 ft. depth

Wet well size App.  
6 ft. X 12 ft. X 6 ft. depth



Type of Collection System Separate

Combined  Separate  Both

Estimate flow contributed by surface or ground water (infiltration)

Very little MGD

Plant Loading Information

Annual average daily flow rate (mgd)

Peak flow rate (mgd)

Dry .10

Dry .12

Wet .14

Wet .16

COMMENTS: \_\_\_\_\_

