

M E M O R A N D U M

March 5, 1975

State of
Washington
Department
of Ecology



TO: VERN MEINZ
FROM: HANS CREGG *HK*
SUBJECT: Ilwaco STP

On December 11, 1974, an efficiency study was conducted at the Ilwaco sewage treatment plant.

The plant is fenced and well-maintained. Lab results indicate that secondary BOD and suspended solids criteria are being met. Coliform levels were extremely high until it was suggested that the operator increase his chlorine flow. It can be readily seen (see report form) that this action resulted in a significant drop in coliform levels. Reductions on a percentage basis were not computed since it is obvious that not the influent but the returned sludge was being sampled.

HJC:bj

STP Survey Report Form

Efficiency Study

City Ilwaco Plant Type Secondary Pop. Served 600 Design Capacity 600
 Receiving Water _____ Perennial _____ Intermittent _____
 Date 12/11/74 Survey Period 8 hours Survey Personnel H. J. Cregg
 Comp. Sampling Frequency hourly Sampling Alequot 1000 mls
 Weather Conditions (24 hr) _____ Are facilities provided for complete by-pass of raw sewage? _____ Yes _____ No/Frequency of bypass _____
 Reason for bypass _____ Is bypass chlorinated? _____ Yes _____ No
 Was DOE Notified? _____ Discharge - Intermittent _____ Continuous _____

Plant Operation

Total flow 120,000 GPD How measured Totalizer
 Maximum flow _____ Time of Max. _____
 Minimum flow _____ Time of Min. _____
 Pre Cl₂ _____ #/day Post Cl₂ _____ #/day

Field Results

Influent

Effluent

<u>Determinations</u>	<u>Max.</u>	<u>Min.</u>	<u>Mean</u>	<u>Median</u>	<u>Max.</u>	<u>Min.</u>	<u>Mean</u>	<u>Median</u>
Temp °C	14	13		14	13			13
pH (Units)	5.5	5.0		5.3	5.4	5.2		5.2
Conductivity (µmhos/cm ²)	350	250		300	300	300		300
Settleable Solids (mls/l)	160	150	150	150	NEG	NEG	NEG	NEG

Laboratory Results on Composites

	<u>Influent</u>	<u>Effluent</u>	<u>% Reduction</u>
Laboratory No.	<u>74-4843</u>	<u>74-4844</u>	
5-Day BOD ppm	<u>>810</u>	<u>28</u>	
COD ppm	<u>2650</u>	<u>30</u>	
P.S. ppm	<u>2690</u>	<u>215</u>	
P.N.V.S. ppm	<u>956</u>	<u>124</u>	
P.S.S. ppm	<u>2696</u>	<u>19</u>	
I.V.S.S. ppm	<u>894</u>	<u>1</u>	
pH (Units)	<u>6.3</u>	<u>6.2</u>	
Conductivity (µmhos/cm ²)	<u>280</u>	<u>280</u>	
Turbidity (JTU's)	<u>600</u>	<u>12</u>	

Laboratory Bacteriological Results

Lab No.	Sampling Time	Colonies/100 ml (MP)			Cl ₂ Residual	
		Total Coliform	Fecal Coliform	Fecal Strep		
74-4845	1100	Est 44000	1200		.0	.1
74-4846	1200	Est 50000	1200		.0	.0
74-4847	1400	Est 120	<10		.75	<1.0
74-4848	1500	Est 20	<10		>1.0	>1.0

Additional Laboratory Results

NO ₃ -N ppm -	11.08
NO ₂ -N ppm -	0.02
NH ₃ -N ppm -	0.22
T. Kjeldahl-N ppm -	3.00
O-PO ₄ -P ppm -	1.10
T-PO ₄ -P ppm -	1.60

Operator's Name Larry Wallin Phone No. 642-3598

Furnish a flow diagram with sequence and relative size and points of chlorination.

Type of Collection System

Combined Separate Both

Estimate flow contributed by surface or ground water (infiltration)

_____ MGD

Plant Loading Information

Annual average daily flow rate (mgd)

Peak flow rate (mgd)

Dry _____

Dry _____

Wet _____

Wet _____

COMMENTS: _____

