

M E M O R A N D U M

May 10, 1976

To: Ron Robinson

From: Douglas Houck

Subject: Port Angeles STP  
Class II Inspection

On January 6, 1976 we arrived at the Port Angeles sewage treatment plant. Three composite samplers were installed and adjusted to take a 250 ml aliquot every 30 minutes. The first sampler was located after the barminutor and the other two samplers were located before and after chlorination. The plant has no chlorine contact chamber per se but uses its discharge pipe to serve the same purpose. The grab samples for fecal coliform and chlorine residual were taken from a manhole located approximately 300 yards from the application point of chlorine.

In reviewing their laboratory procedures several deficiencies were noted. They were not using the four nutrient buffers to make up the dilution water for their BOD<sub>5</sub>'s and the temperature of their hot water bath was only 44.0°C.

The accuracy of the plant's 36-inch Parshall flume was checked and found to be correct within 2 percent. This is quite good.

On the 7th I returned to pick up and split the composite samples and take a fecal grab sample along with a grab sample of their digested sludge to be analyzed for heavy metals. The following table shows DOE's and Port Angeles' results along with their NPDES monthly average limitations. Port Angeles reported only BOD<sub>5</sub> values.

	DOE		Port Angeles		NPDES
	Inf.	Eff.	Inf.	Eff	Monthly Avg.
BOD <sub>5</sub> (mg/l)	100	80	160	100	133
TSS (mg/l)	133	47			100
Fecal Coliform (colonies/100 ml)		Est 90			700
Chlorine Residual (mg/l)		2.4			Min. 0.5

Although well within their permit limitations the results show that there wasn't good correlation between Port Angeles' and DOE's BOD<sub>5</sub> values. This should be something that should be looked into on the next Class II inspection.

DH:ee

STP Survey Report Form

Efficiency Study

City Pt. Angeles Plant Type Primary Pop. Served 16,000 Design Capacity 24,400  
 Receiving Water Puget Sound Perennial X Intermittent \_\_\_\_\_  
 Date 1-6/7-76 Survey Period 24 hrs. Survey Personnel Houck, Robinson  
 Comp. Sampling Frequency 30 min. Sampling Alequot 250 ml  
 Weather Conditions (24 hr) dry, cool Are facilities provided for complete by-pass of raw sewage? X Yes \_\_\_\_\_ No/Frequency of bypass 1-2/yr.  
 Reason for bypass oil slick Is bypass chlorinated? X Yes \_\_\_\_\_ No  
 Was DOE Notified? Yes Discharge - Intermittent \_\_\_\_\_ Continuous X

Plant Operation

Design  
 Total flow 10.1 MGD How measured Sparling recorder (Parshall 36")  
 Maximum flow 5.0 MGD Time of Max. 0900  
 Minimum flow \_\_\_\_\_ Time of Min. 0230  
 Pre Cl<sub>2</sub> - - #/day Post Cl<sub>2</sub> 339 - 100 #/day

Field Results

Determinations	Influent				Effluent			
	Max.	Min.	Mean	Median	Max.	Min.	Mean	Median
Temp °C				9.9				
pH (Units)				6.8				6.8
Conductivity (µmhos/cm <sup>2</sup> )								
Settleable Solids (mls/l)								

Laboratory Results on Composites

	Influent	Effluent	% Reduction
Laboratory No.	<u>76-0041</u>	<u>76-0043</u>	
5-Day BOD ppm	<u>100</u>	<u>&lt;80</u>	<u>&gt;20.0%</u>
COD ppm	<u>160</u>	<u>145</u>	<u>9.4%</u>
T.S. ppm	<u>348</u>	<u>318</u>	<u>8.6%</u>
T.N.V.S. ppm	<u>140</u>	<u>188</u>	<u>- 92.0%</u>
T.S.S. ppm	<u>133</u>	<u>47</u>	<u>64.7%</u>
N.V.S.S. ppm	<u>22</u>	<u>2</u>	<u>90.9%</u>
pH (Units)			
Conductivity (µmhos/cm <sup>2</sup> )			
Turbidity (JTU's)			

Laboratory Bacteriological Results

Lab No.	Sampling Time	Colonies/100 ml (MF)			Cl <sub>2</sub> Residual
		Total Coliform	Fecal Coliform	Fecal Strep	
	1000		Est. 90		2.4

Additional Laboratory Results

NO <sub>3</sub> -N ppm -	0.74
NO <sub>2</sub> -N ppm -	0.02
NH <sub>3</sub> -N ppm -	6.3
T. Kjeldahl-N ppm -	
O-PO <sub>4</sub> -P ppm -	2.5
T-PO <sub>4</sub> -P ppm -	3.9

Operator's Name Ken Rodocker Phone No. 457-0411

Furnish a flow diagram with sequence and relative size and points of chlorination.

Type of Collection System

Combined  Separate  Both

Estimate flow contributed by surface or ground water (infiltration)

Study done this year 3 MGD

Plant Loading Information

Annual average daily flow rate(mgd)

Peak flow rate(mgd)

~~XXX~~ 1.5 MGD

Dry \_\_\_\_\_

~~XXX~~ \_\_\_\_\_

Wet \_\_\_\_\_

COMMENTS: \_\_\_\_\_


# LANT

and interceptor system enters  
 r influent sewer at the grit  
 y that of a combined system,  
 nd other heavy inert material.  
 material in advance of pumps  
 machine wear and excessive  
 nk and digesters. In the grit  
 gh to allow heavy particles to  
 eep lighter organic material in  
 tment unit. The collected grit  
 disposal by landfill.

various other kinds of clogging  
 ds are shredded in the sewage  
 1/4-inch maximum. Generally,  
 or clog pumps or treatment  
 ter, and allow disinfectants to

he flow measuring flume (3).  
 recorded, and is the basis for

e, the flow is to the clarifier  
 remove as much as possible of  
 een 40 and 60 percent. It is  
 300 parts per million (0.03  
 l causes the major problems  
 al is accomplished by allowing  
 s. As the solids settle to the  
 usly raked to the center well  
 n to the primary digester (6).  
 is chlorinated and discharged






## DESCRIPTION (CONTINUED)

Sludge collected in the  
 water (95 percent plus) be  
 The digesters (6 and 7) serv  
 along with the more impo  
 matter. This is done by allo  
 for certain bacteria. The d  
 facilitate better control of  
 continually mixed and kept  
 more rapid decomposition.  
 digested sludge is automatic  
 (7) where further decomposi  
 sludge is stored and dried in  
 in liquid form to tank trucks

Major products of digestic  
 gas. The methane gas is  
 secondary digester (7) and is  
 is used to keep the primary  
 gas is burned at the waste ga

Complete laboratory facili  
 (10) for treatment process e  
 also contains the chlorinatio  
 and control piping system.



STATE OF WASHINGTON  
DEPARTMENT OF ECOLOGY

OLYMPIA LABORATORY

DATA SUMMARY

ORIGINAL TO:  
D. Houck.....  
COPIES TO:  
R. Robinson...  
.....  
.....  
LAB. FILES.....

Source Port Angeles STP

Collected By D. Houck

Date Collected 1-6/7-76

Log Number:	76-0041	42	43	44	45					
Station:	INF	UNCOR. EFF	CHLOR. EFF	0945	ANAEROBIC DIGEST. SLUDGE					
pH										
Turbidity (NTU)										
Sp. Conductivity (umhos/cm)										
COD	160.	130.	145.							
BOD (5 day)	100	<80.	<80.							
Total Coliform (Col./100ml)										
Fecal Coliform (Col./100ml)				EST 90						
NO3-N (Filtered)			0.74							
NO2-N (Filtered)			0.02							
NH3-N (Unfiltered)			6.3							
T. Kjeldahl-N (Unfiltered)										
O-PO4-P (Filtered)			2.5							
Total Phos.-P (Unfiltered)			3.9							
Total Solids	348	290	318							
Total Non. Vol. Solids	140	172	188							
Total Suspended Solids	133	48	47							
Total Sus. Non Vol. Solids	22	1	2							
Copper (mg/kg)					33.					
Cadmium "					0.8					
Zinc "					170.					
Chromium "					9.2					
Lead "					46.					

Note: All results are in PPM (mg/L) unless otherwise specified. ND is "None Detected"  
" < " is "Less Than" and " > " is "Greater Than"